
PLAN SUBMITTAL CHECKLIST

PRE-ENGINEERED FIRE SUPPRESSION SYSTEM INSTALLATION & REPLACEMENT

The following information shall be provided on all documents submitted for Plan Approval for Pre-Engineered Fire Suppression Systems:

- ☐ 1. Does the scope of work involve the installation of a new Exhaust system, or the modification to an existing exhaust system?
 ___ No (if no, please make note on plans to this effect)
 ___ Yes (if yes, plans and specifications of this work must be provided from a registered design professional, along with the applicable review fees)
- ☐ 2. Is the scope of this work limited to the replacement only of the U.L. 300 pre-engineered suppression system piping only?
 ___ Yes
 ___ No (if no, any work involving fire alarm interconnections, structural or electrical work must be submitted by a registered design professional, along with the applicable review fees)
- ☐ 3. Provide exhaust hood and duct details from hood to exhaust fan termination.
- ☐ 4. Indicate pipe sizes and materials, nozzle types and flow point calculations.
- ☐ 5. Indicate Certified Installer Certification numbers.
- ☐ 6. Indicate manual pull station locations.
- ☐ 7. Indicate power/fuel shut-off to appliances.
- ☐ 8. Indicate discharge warning signage.
- ☐ 9. Provide a copy of the system design manual along with cylinder capacities and locations.
- ☐ 10. Provide a kitchen plan and appliance information